



Number	KIP-16000/G	Scope	Regulation (EU) 2016/426
Issue date	29-10-2018	Module	B
Expire date	28-10-2028		
PIN	0476CT2450	Report	2002450/2
Replaces	KIP-15939/G	Page	1 of 1

EU TYPE-EXAMINATION CERTIFICATE

Kiwa Cermet Italia declares that the products type:

Central heating condensing boilers

Trade mark: **RIELLO**

Models: TAU Unit 35, TAU Unit 50, TAU Unit 70, TAU Unit 100, TAU Unit 115, TAU Unit 140, TAU Unit 190

Placed on the market by **RIELLO S.p.A.**

Via Ing. Pilade Riello, 7, 37045 Legnago (VR), Italy

meet the essential requirements as described in the

Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Appliance type: B₂₃, B_{23P}, B_{53P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃ (only for models TAU Unit 35, TAU Unit 50, TAU Unit 70, TAU Unit 100, TAU Unit 115, TAU Unit 140)

Appliance type: B₂₃, B_{23P}, B_{53P}, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃ (only for model TAU Unit 190)

Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Related to the following gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	E(S)	20	Esi	20/25
H	20;25	E(R)	20	P	37

The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.

The assessment test have been performed using the following standards as guidelines:

EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016

The validity of this certificate can be verified on request at the following e-mail address: info@kiwa.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Chief Operating Officer
Giampiero Belcredi



SGQ N° 007A
SGA N° 010D
PRD N° 069B
FSM N° 004I
PRS N° 089C

